

Shelter Inspections

When a shelter is established due to a flood or other disaster, the Division of Fire Safety shall make a site visit before sleeping occurs in that shelter. The inspection will look at;

- Smoke detection operability
- Carbon Monoxide detection operability
- Means of Egress, free and clear of obstructions
- Fire Extinguishers present
- All fire protection systems are functional, if present.

The Division of Fire Safety will notify the local fire department and EMS that a shelter is in operation in their jurisdiction.